



## CLEAN AGENT SYSTEMS SUBMITTALS

Information Required for Submittal to be reviewed by FSCI

**See NFPA 2001 for a complete submittal list.**

- Plans must be to scale and clearly show all work to be done.
- Plans must show the job name and complete address.
- A key plan shall be provided showing the area of work in the building.
- Complete catalog cut sheets shall be provided for all equipment to be used.
- The scope of work shall include a description of hazard being protected and type/manufacturer of agent being used.
- Calculations for required agent quantity and discharge time shall be provided.
- All alarm portions of the system shall comply with the submittal requirements of a fire alarm system.

Information Contact:	Pleasant Prairie Fire & Rescue <a href="mailto:fire rescue@pleasantprairiewi.gov">fire rescue@pleasantprairiewi.gov</a> 262.694.8027
----------------------	--