



KITCHEN WET CHEMICAL SUBMITTALS

Information Required for Submittal to be reviewed by FSCI

See NFPA 17a for a complete submittal list.

- Plans must include exact hood, duct, piping, and appliance dimensions. A scaled front elevation and isometric view shall be included.
- Plans must show job name and complete address.
- Catalog cut sheets must be provided for all nozzles and equipment to be used.
- The tank size and flow point count must be noted on the plans.
- All plans must have the contractors name, address, and phone number.
- A plan view of the kitchen must show the hood, tank, and pull station locations.
- The plans must clearly show the type of nozzles to be used and show the mounting height, and aiming point for each.

Information Contact:	Pleasant Prairie Fire & Rescue firerescue@pleasantprairiewi.gov 262.694.8027
----------------------	--